

MICROGRID MARVELS: UNVEILING COMPREHENSIVE RESEARCH ON HYBRID ENERGY STORAGE STRATEGIES

Zhang Yanmei

State Grid Liaoning Electric Power CO, LTD., Power Electric Research Institute, Shenyang 110015, China

Abstract

The multi-circuit coupling transmission mode is an inevitable trend of power grid construction, mainly with partially coupled multi-circuit lines. Affected by the local coupling between lines, the existing fault location methods have large errors. To this end, fault analysis and fault location methods are carried out on partially coupled double-circuit transmission lines. According to the structure and characteristics of the partially coupled double-circuit transmission line on the same tower, the voltage and current interface equations at the coupling demarcation point of the partially coupled double-circuit transmission line are established using line decoupling theory. On this basis, a time-domain analysis model of fault location for each coupling section is constructed, and a time-domain method for fault location of partially coupled double-circuit transmission lines is proposed. Finally, the electromagnetic transient simulation software is used to construct a partially coupled double-circuit transmission line model on the same tower, and a comprehensive simulation verification is performed. The results show that the proposed method has high accuracy.

Keywords: Comprehensive research; hybrid energy; fault location; time domain method; DC microgrids

1. Introduction

With the increasingly serious global energy crisis and environmental pollution, clean new energy such as solar energy, wind energy, and nuclear energy has received more attention and expectations. As a key technology for integrating renewable distributed generation systems, energy storage devices and loads into controllable sub-networks, microgrids can work both on-grid and off-grid. Compared with the AC microgrid[1-5], the DC microgrid has a simple structure, high efficiency, good power quality, and does not have the problems of frequency offset, phase synchronization and reactive power compensation, which helps it to be widely popularized and applied. The intermittent power output and load variability of distributed generation devices will not only cause large-scale fluctuations in DC bus voltage, but also lead to power imbalance and reduce the reliability of system power supply. Therefore, energy management and coordinated control of DC microgrids It is one of the key problems to be solved to ensure its stable operation. A method for grid-connected converters to adjust the DC bus voltage is proposed[6-11], but this method does not consider photovoltaic modules and hybrid energy storage modules in the DC microgrid, so the reliability of the system is low and the dynamic response is slow. The energy management method of DC microgrid is the benchmark, but this method ignores the saturated and insufficient power of the hybrid energy storage module, and does not consider the situation that the DC bus voltage is too low when the load is heavy, which may cause the system to collapse. An energy management method based on DC bus voltage information is proposed. This method only considers DC load in DC micro grid and is not suitable for the current power supply mode. In order to stabilize the DC bus voltage and optimize the working process of each module of the system,

this paper proposes a control method for coordinating energy between photovoltaic, hybrid energy storage, and large power grids. Based on the DC bus voltage, the power balance of the system is judged. In the grid-connected state, a grid-connected conversion module is introduced to realize the energy exchange between the DC micro grid and the large power grid to maintain the system power balance; in the off-grid state[12-17], consider hybrid The working characteristics of each energy storage unit and its charge and discharge margin, set the working thresholds of super capacitors and lithium batteries, manage the energy output of photovoltaic and hybrid energy storage, improve the dynamic response speed of the system, avoid frequent actions of power electronic devices, and prolong the use of life.

The system can be divided into 6 energy management modes, and can switch smoothly between the 6 energy management modes, maintaining the stability of the DC bus voltage and ensuring the reliable and stable operation of the system[18-21].

2. DC microgrid structure

The structural block diagram of the DC microgrid is composed of photovoltaic PV (photovoltaic) module, hybrid energy storage (HES) module, grid-connected converter GC (grid converter) module and load 4. The photovoltaic module is connected through the Boost circuit. On the DC bus the hybrid energy storage module is composed of a super capacitor, a lithium battery and a Buck/Boost bidirectional converter, which can freely switch charge and discharge according to the real-time balance state of energy supply and demand in the microgrid system; the grid-connected converter adopts a three-phase bridge circuit, which can realize micro grid and large grid energy interaction between; local load DC/DC, DC/AC converter and resistive load simulation. In the overall structure of the energy management method, the photovoltaic module can be freely switched between the maximum power tracking (MPPT maximum power point trace) and the constant voltage mode, which improves the operating efficiency of the system; the hybrid energy storage module includes super capacitors and lithium batteries, using droop control and current The inner loop PI control method can freely switch between charging, discharging, standby and current limiting modes, avoiding unnecessary actions of power electronic devices caused by small-scale fluctuations in the DC bus voltage, and improving the service life of the hybrid energy storage module; grid-connected The converter module can switch freely between rectification, inverter and shutdown modes, and can determine the size and direction of energy transmission between the microgrid and the large grid according to the real-time balance of system power.

Since the DC microgrid does not need to consider the reactive power, frequency, phase and other issues, the DC bus voltage becomes the main parameter reflecting the power balance of the microgrid. By monitoring the fluctuation of the DC bus voltage U_{dc} , the energy exchange between the distributed power source, the energy storage module, the large grid and the load is managed in sections, reducing the frequency of frequent switching of some converters and ensuring the reliable operation of the microgrid. When it is detected that $UL2 \leq U_{dc} \leq UH2$ ($UL2$ and $UH2$ are the working critical values of grid-connected converters), the grid-connected converter (GC) stops and the system is in an off-grid state. According to the system power balance, the photovoltaic modules and hybrid The energy storage output is subdivided into 4 working modes; when the DC bus low voltage $U_{dc} \leq UL2$ or $U_{dc} \geq UH2$ is detected, the hybrid energy storage module adopts standby control, and the grid-connected converter determines the amount of transmitted energy and direction.

3. System energy management mode

The grid-connected converter adopts shutdown control, and the system is in an off-grid state; in order to prevent the frequent operation of the hybrid energy storage module caused by the small-scale fluctuation of the DC bus voltage, the super capacitor and lithium battery adopt standby control; the

photovoltaic module adopts constant voltage control, which continuously provides load For power supply, the power generated by the photovoltaic module and the power consumed by the load are balanced. The grid-connected converter adopts shutdown control, and the system is in an off-grid state; due to the surplus system power, the hybrid energy storage module ensures the system power balance by absorbing power. When the voltage U_{sc} at both ends reaches a certain value, the lithium battery is put into work again and begins to charge, maintaining the constant DC bus voltage; as the super capacitor and lithium battery continue to charge, neither of them reaches saturation, the photovoltaic module adopts MPPT control, the photovoltaic module emits power. The energy efficiency, the hybrid energy storage module absorbed power and the load consumption power are balanced. The grid-connected converter adopts shutdown control, and the system is in an off-grid state; due to the surplus system power, the hybrid energy storage module ensures the system power balance by absorbing power. When the voltage U_{sc} at both ends reaches a certain value, the lithium battery is put into work again and begins to charge, maintaining the constant DC bus voltage; as the super capacitor and lithium battery continue to charge, both of them reach saturation, that is, the hybrid energy storage module When the state of charge is not less than 90%, the photovoltaic module adopts constant voltage control, and the super capacitor and lithium battery adopts current limiting control. The power emitted by the photovoltaic module, the absorbed power of the hybrid energy storage module and the power consumed by the load are balanced. The grid-connected converter adopts shutdown control and the system is in an off-grid state; due to insufficient system power, the hybrid energy storage module releases power to ensure system power balance. Super electric Rong first put into work, using discharge control, and began to discharge. When the voltage U_{sc} at both ends reaches a certain value, the lithium battery starts to work again and begins to discharge, maintaining the constant DC bus voltage; with the continuous discharge of the super capacitor and the lithium battery, neither of them reaches the limit of power. If sufficient, the photovoltaic module adopts MPPT control, and the output power of the photovoltaic module, the power released by the hybrid energy storage module and the power consumption of the load are balanced. The grid-connected converter adopts inverter control, and the system is in grid-connected state; as the super capacitor and lithium battery are in standby state, the photovoltaic module adopts MPPT control, but the DC bus voltage cannot be reduced to near the rated value, so the grid-connected converter will The remaining power of the system is transmitted to the large power grid, and the photovoltaic module adopts MPPT control, so that the power generated by the photovoltaic module, the transmission power of the grid-connected converter and the power consumption of the load are balanced. The grid-connected converter adopts rectification control, and the system is in grid-connected state; as the super capacitor and lithium battery are in standby state, the photovoltaic module adopts MPPT control, but the DC bus voltage cannot rise to near the rated value, so the insufficient power of the system is determined by the large Power grid supply, so that the output power of photovoltaic modules, the input power of grid-connected converters and the power consumption of loads are balanced.

4. Photovoltaic module circuit and control

In order to avoid the frequent operation of the hybrid energy storage module caused by the small-scale fluctuation of the DC bus voltage, combined with the fast dynamic response of the super capacitor and the high energy density of the lithium battery, the DC bus voltage deviation reference is set, and the hybrid energy storage module allows the super capacitor to work and balance first. The instantaneous power of the system improves the dynamic response of the system, reduces the number of actions of the lithium battery, and prolongs the service life; after the lithium battery works, the DC bus voltage is adjusted with the super capacitor to prevent the super capacitor from reaching saturation too fast. In order to fully and efficiently utilize the output of the distributed power supply and the adjustment

capability of the energy storage device, and improve the operation efficiency of the DC microgrid, the operating voltage threshold of the grid-connected converter is set so that it can freely switch between rectification, inverter and shutdown modes, avoiding the small range of bus voltage. The fluctuations cause frequent actions of the power electronic devices, which improves the power quality of the system. The system switches from mode 1 to mode 2. The output power of the photovoltaic panel is higher than the power consumed by the load, so that the DC bus voltage is raised. When it is detected that the DC bus voltage U_{dc} reaches the working threshold for charging the supercapacitor, the supercapacitor starts to charge with a current of 1.9A, and the voltage across the supercapacitor will increase as it continues to charge, but before reaching the working threshold for charging the lithium battery, the current of the lithium battery is still 0. When it is detected that the voltage across the supercapacitor reaches the minimum working threshold of 11 V for charging the lithium battery, the lithium battery starts to work and its current slowly increases from 0. The super battery and the lithium battery work in coordination to absorb the excess power of the system, and the DC bus voltage gradually decreases, which also reduces the charging current of the supercapacitor.

5. Conclusion

The unstable output of the distributed power supply in the DC microgrid will not only cause large-scale fluctuations in the DC bus voltage, but also lead to power imbalance, which makes the system unreliable. In this regard, this paper proposes an energy management optimization method for DC microgrids including photovoltaics and hybrid energy storage, which can quickly stabilize the bus voltage fluctuations caused by the imbalance of system power supply and demand. In the grid-connected state, the DC microgrid exchanges energy with the large grid through the grid-connected converter; in the off-grid state, the photovoltaic module and the hybrid energy storage module coordinate and cooperate to supply power to the local load, avoiding the small-scale fluctuation of the DC bus voltage. Power electronic devices operate frequently, so that new energy and energy storage give priority to power supply to the load. When the load suddenly changes, the energy storage module allows the supercapacitor to work first to stabilize balance the instantaneous power of the system, put the lithium battery into operation, adjust the DC bus voltage with the super capacitor, prevent the super capacitor from reaching saturation too fast, improve the dynamic response speed of the system, prolong the service life of the energy storage unit, and maintain the system power Balance, to achieve the optimal use of energy.

References

- MA L, ZHANG X. Economic operation evaluation of active distribution network based on fuzzy borda method [J]. IEEE Access, 2020, 8: 29508-29517.
- GE L, LI Y, LI S, et al. Evaluation of the situational awareness effects for smart distribution networks under the novel design of indicator framework and hybrid weighting method[J]. Frontiers in Energy, 2021, 15(1): 143-158.
- KONG X Y, YONG C S, WANG C S, et al. Multi-objective power supply capacity evaluation method for active distribution network in power market environment[J]. International Journal of Electrical Power & Energy Systems, 2020: 115: 105467.

- Cheng Mingxi. Binomial coefficient weighted sum method for multi-objective decision-making problems [J]. Department System Engineering Theory and Practice, 1983(4): 23-26.
- HU C, LIU F, HU C. A hybrid fuzzy DEA/AHP methodology for ranking units in a fuzzy environment [J]. Symmetry-Basel, 2017, 9(11): 273.
- Li Zhijun, Xiang Jianjun, Sheng Tao, et al. Improvement based on G1-coefficient of variation-KL TOPSIS Radar Jamming Effectiveness Evaluation [J/OL]. Beijing University of Aeronautics and Astronautics Newspaper: 1-11 [2021-12-06]. <https://doi.org/10.13700/j.bh.1001-5965>. 2020. 0493. [7] Kong Ming, Han Xiaotong. Study on particle diffusion law based on standard device [J]. China Test, 2019, 45(4): 35-42.
- YU Yang, XIE Renjie, LU Jianbin, et al. Modeling and controlling of aggregated thermostatically controlled loads for smoothing power fluctuation of renewable energy sources[J]. Smart Power, 2020, 48(3): 69-75.
- Li Hongzhong, Fang Yujiao, Xiao Baohui. Optimization of regional comprehensive energy system considering generalized energy storage research on chemical operation [J]. Power Grid Technology, 2019, 43(9): 3130-3138.
- Li Hongzhong, Zhang Yi, Sun Weiqing. Wind power power considering generalized energy storage under wavelet packet decomposition volatility stabilization strategy [J]. Power Grid Technology, 2020, 44(12): 4495-4504.
- SONG M, GAO C W, YAN H G, et al. Thermal battery modelling of inverter air conditioning for demand response [J]. IEEE Transactions on Smart Grid, 2018, 9(6): 5522-5534.
- Li Hongzhong, Lv Menglin, Hu Liexiang, et al. Joint planning of microgrid considering generalized energy storage [J]. Electric Power Automation Equipment, 2020, 40(7): 149-160.
- Wang D X, MENG K, GAO X D, et al. Coordinated dispatch of Virtual energy storage systems in LV grids for voltage regulation [J]. IEEE Transactions on Industrial Information, 2018, 14(6): 2452-2462.
- Yong Jing, Xu Xin, Zeng Liqiang, et al. A review of low voltage DC power distribution system[J]. Proceedings of the CSEE, 2013, 33(7): 42-52(in Chinese).
- Xiong Xiong, Wang Hongbo, Yang Rengan, et al. A fuzzy adaptive control strategy for composite energy storage system to cope with output power fluctuation of intermittent energy source in microgrid[J]. Power System Technology, 2015, 39(3): 677-681(in Chinese).
- Wu T F, Sun K H, Kuo C L, et al. Predictive current controlled 5 kW single-phase bidirectional inverter with wide inductance variation for DC-microgrid applications[J]. IEEE Transactions on Power Electronics, 2010, 25 (12): 3076-3084.
- Radwan A A A, Mohamed Y A I. Linear active stabilization of converter-dominated DC microgrids [J]. IEEE Transactions on Smart Grid, 2012, 3(1): 203-216.

- Anand S, Fernandes B G, Guerrero J. Distributed control to ensure proportional load sharing and improve voltage regulation in low voltage DC microgrids[J]. IEEE Transactions on Power Electronics, 2013, 28(4): 1900-1913.
- Zhang Xue, Pei Wei, Deng Wei, et al. Energy management and coordinated control method for multi-source/multi-load DC microgrid[J]. Proceedings of the CSEE, 2014, 34(31):5553-5562(in Chinese).
- Gustavo G, Hamilton C, Kerley R, et al. Control strategy of a multi-port grid connected direct DC PV charging station for plug-in electric vehicles[C]. 2010 IEEE Energy Conversion Congress and Exposition. Atlanta, USA, 2010: 1173-1177.
- Bryan J, Duke R, Round S. Decentralized generator scheduling in a nanogrid using DC bus signaling[C]. 2004 IEEE Power Electronic Systems. Denver, USA, 2004(1): 977-982.